



Offering unique zoning capabilities which permit the averaging and comparison of multiple sensor readings

The VA301C continuously monitors and controls toxic gases, combustible gases, and oxygen hazards. Designed for installation and operational simplicity, the VA301C reduces the cost of installation and ownership.

Using an addressable RS-485 Modbus communication protocol, the 301C uses daisy chain wiring requiring only 2 pairs of wires to connect up to 96 transmitters on the 3 input channels. This simplifies installation, in turn lowering costs. The 301C's zoning and averaging abilities significantly reduce operational and maintenance costs.



Zoning/Averaging Capabilities Reduce Operational Costs

The 301C controller offers unique zoning capabilities which permit the averaging and comparison of multiple sensor readings. Zoning can reduce operational costs by ensuring that localized brief fluctuations registered at a single transmitter do not activate relays. For example, a car idling in a parking structure may locally increase a reading at a nearby transmitter. Rather than activating a fan as a result of the temporary localized fluctuation, zoning can be used to limit relay activation until the average reading for a zone exceeds a set-point. This can reduce run time of fans, yielding savings in both energy usage and wear and tear. The 301C has the capacity to manage input from three Modbus channels for up to 96 transmitters and up to 50 wireless transmitters which can be associated with up to 126 zones. Transmitters can belong to an unlimited number of zones, providing maximum operational and control flexibility.

Find out more

www.honeywellanalytics.com

Contact Honeywell Analytics:

Honeywell Analytics Inc.
4005 Matte Blvd., Unit G
Brossard, QC, Canada
J4Y 2P4
Tel: +1 450 619 2450
Toll free: +1 800 563 2967
Fax: +1 888 967 9938

Technical Services

ha.service@honeywell.com

www.honeywell.com

User Friendly

- Zero maintenance
- Automatic quick self-test and warm-up
- Continuous alphanumeric display

Inexpensive and Reliable

- Low installation costs
- Allows for up to 126 zoning groups which can save energy and extend fan and relay life
- Manages up to 768 events with programmable latching alarms

Flexible Operation

- Modbus compatible; with BACnet/IP available
- Interchangeable transmitters able to detect different gases
- Expands to handle up to 96 transmitters or relay modules and up to 50 301W wireless sensors
- Programmable time delays
- Integrated time clock enables scheduling of system operations

Safety Measures

- Full array of visual indicators and integrated 65dBA alarm levels
- Fully programmable relays (can be set as fail-safe or not)

Beneficial Options

- Available in a heavy duty industrial housing
- Datalogging option

General Specifications	
Use	Modbus controller for centralized gas detection monitoring with real-time gas reading, selective alarm activation and low cost of installation.
Size	28 x 20.3 x 7 cm (11.02 x 7.99 x 2.76 in.)
Weight	1.1 kg (2.4 lb.)
Power Requirement	17-27 Vac, 24-38 Vdc, 500 mA
Network Capacity	Three Modbus channels for up to 96 transmitters, one wireless channel for up to 50 301W wireless transmitters and an optional BACnet/IP output
Communication Line Lengths	Up to 609 m (2000 ft.) per channel T-Tap: 20 m (65 ft.), maximum per T-Tap 40 m (130 ft.), maximum for all T-Tap combined
Relay Output Rating	5 A, 30 Vdc or 250 Vac (resistive load)
Alarm Levels	3 fully programmable alarm levels
Time Delays	0, 30 sec., 45 sec., 1-99 minutes before and after alarm
Outputs	4 DPDT relays (alarms and/or fault); 65dBA buzzer
Display	Large 122 x 32 dot matrix display
Operating Humidity Range	0-95% RH, non-condensing
Operating Temperature Range	-20 to 50°C (-4 to 122°F)
Ratings and Certifications	
Certified to	CAN/CSA C22.2 No 61010-1 FC ETL 116662
Conforms to	ANSI/UL 61010-1 IEC 61010-1 Including Amendments A1:1992 + A2:1995 and National Deviations (Canada, US)

Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.
© 2007 Honeywell Analytics

H_301C_DS01015_V3
10/09
© 2009 Honeywell Analytics

Honeywell